



CB TEST CERTIFICATE

Ref. Certificate No.

TR-00875

IEC SYSTEM OF CONFORMITY ASSESSMENT SCHEMES FOR ELECTROTECHNICAL EQUIPMENT AND COMPONENTS (IECEE) CB SCHEME

Issued by:	TSE Certification Center		
Product:	Socket-Outlets		
Applicant:	TEM TEKNİK ELEK. MALZ. SAN. VE TIC. A. S	SELIMPASA ORTAKOY SANAYI BOLGESI ILTER BULVARI YEL DEGIRMENI CADDESİ MOR MENEKSE SOKAK NO:5 SILIVRI /İSTANBUL	Turkey
Manufacturer:	TEM TEKNİK ELEK. MALZ. SAN. VE TIC. A. S TRIK SAN. VE TIC. A.S	SELIMPASA ORTAKOY SANAYI BOLGESI ILTER BULVARI YEL DEGIRMENI CADDESİ MOR MENEKSE SOKAK NO:5 SILIVRI /İSTANBUL	Turkey
Factory:	TEM TEKNİK ELEK. MALZ. SAN. VE TIC. A. S	SELIMPASA ORTAKOY SANAYI BOLGESI ILTER BULVARI YEL DEGIRMENI CADDESİ MOR MENEKSE SOKAK NO:5 SILIVRI /İSTANBUL	Turkey
Rating and principal characteristics:	16 A , 250 V ~, INCREASED PROTECTION, IP 54, PANEL TYPE, WITH SHUTTERS, DESIGN B, SCREW-TYPE, TWO-POLE, SOCKET-OUTLETS WITH PIN TYPE EARTHING CONTACTS		

Trade mark (if any): TEM

Customer's Testing Facility (CTF) Stage used:

Model/Type reference: 21X.216.1XX
First X: Earthing type of product (7: Pin type earthing contact)
Second and Third X: Shutters code (60: with shutter)

Additional information: National Standard Plugs and socket outlets for household and similar purposes -, Standard sheets (Sheet 9=CEE 7:Sheet V) is applied

Sample of product tested to be in conformity with IEC: Standard(s):
IEC 60884-1:2002
IEC 60884-1:2002/AMD1:2006
IEC 60884-1:2002/AMD2:2013
Comments:
TS 40 National Standard (Sheet 9=CEE 7:Sheet V)

Test Report Ref. No: 633672

This CB Test Certificate is issued by the National Certification Body:

TSE Certification Center
Necatibey Cad. No: 112, TR-06100 Bakanliklar, Ankara, Turkey

Signed by: Soydan Ceran

Date of issue: 2021-12-21

