

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	SOCKET-OUTLETS
Name and address of the applicant	TEM TEKNİK ELK. MALZ. SAN. VE TIC. A.S. SELIMPASA ORTAKOY SAN. BOL. ILTER BLV. YEL DEGIRMENİ CAD. MOR MENEKSE SOK. NO:5 SILIVRI/İSTANBUL Turkey
Name and address of the manufacturer	TEM TEKNİK ELK. MALZ. SAN. VE TIC. A.S. SELIMPASA ORTAKOY SAN. BOL. ILTER BLV. YEL DEGIRMENİ CAD. MOR MENEKSE SOK. NO:5 SILIVRI/İSTANBUL Turkey
Name and address of the factory	<input type="checkbox"/> Additional information on page 2 TEM TEKNİK ELK. MALZ. SAN. VE TIC. A.S. SELIMPASA ORTAKOY SAN. BOL. ILTER BLV. YEL DEGIRMENİ CAD. MOR MENEKSE SOK. NO:5 SILIVRI/İSTANBUL Turkey
Note: When more than one factory, please report on page 2	
Ratings and principal characteristics	16 A , 250 V ~, NORMAL PROTECTION, SCREW TYPE, DESIGN A, FLUSH TYPE , WITHOUT SHUTTER, TWO POLE, WITH SIDE EARTHING CONTACT SOCKET-OUTLETS
Trademark (if any)	TEM
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	346.X16.150
Additional information (if necessary may also be reported on page 2)	<input type="checkbox"/> Additional information on page 2
A sample of the product was tested and found to be in conformity with	IEC 60884-1:2002/AMD1:2006, IEC 60884-1:2002/AMD2:2013 National differences: TR Comments: TS 40 National Standard (Sheet 7=CEE 7:Sheet III) 459284/03-19 ,TR-06-14-10-01/0482/00004
As shown in the Test Report Ref. No. which forms part of this Certificate	

This CB Test Certificate is issued by the National Certification Body

TSE
Necatibey Cad. No: 112, TR-06100 Bakanlıklar, Ankara, Turkey



